



Wastewater Treatment Plant Municipality



Key Facts

Installed:	2008
Operating hours since:	44,000h (Aug 2013)
Installation Time:	5 days
Power Output:	2.80 MW _{el}
Storage Volume:	2 x 3,500m ³
Gas production:	3,000m ³ /h
Operating pressure:	25 mbar
Gasholder Diameter:	20.0m
Gasholder Height:	15.0m